

**NOTES:**

1. REFER TO NU-VUE WEBSITE FOR MOST CURRENT INFORMATION.
2. REFER TO TECHNICAL INFORMATION SHEETS FOR FASCIA SIZES, ACCESSORIES, AND FINISHES AVAILABLE.
3. REFER TO THE NU-VUE TECHNICAL DATABASE FOR HEM LENGTH AND REQUIRED DISTANCE BETWEEN THE PANEL & CLEAT.
4. REFER TO THE NU-VUE TECHNICAL DATABASE FOR FASTENER COMPATIBILITY WITH METAL.
5. STAGGER ADJACENT END LAPS MINIMUM 12" (307.2 mm) O.C..

**EXPLODED VIEW**

**FINISHED VIEW**

INSULATION  
(OPTIONAL)

SUBSTRATE

**END LAP**

ACCEPTABLE SYSTEMS: **NV 1.5" & NV 2" STANDING SEAM**

MIN. 6" (152.4 mm) WIDE APPROVED UNDERLAYMENT

(3) CONTINUOUS BEADS OF 1/4" DIA (6.4 mm) BUTYL SEALANT

CONTINUOUS STARTER STRIP SET IN 3/16" x 7/8" (4.8 mm x 63.5 mm) BUTYL TAPE

1" (25.6 mm) MIN.

6" (153.6 mm) MIN.

FIELD TRIM TOP OF SEAM TO ALLOW FOR NESTING

APPROVED UNDERLAYMENT

APPROPRIATE FIRESTONE FASTENER SEE DETAIL R-1 FOR FASTENER SEQUENCE



Job Name:	
Date:	
Contractor:	Notes: